

**Tabela regulacji temperatur wody instalacyjnej
dla ogrzania pompowego 80/64°C
dla MPEC Sp. z o.o. w Lęborku**

Temperatura zewnątrzna /°C/	Temperatura zasilania /°C/	Temperatura powrotu /°C/
- 16	80,0	64,0
- 15	78,5	63,0
- 14	77,0	62,0
- 13	76,0	61,0
- 12	74,5	60,0
- 11	73,0	59,0
- 10	72,0	58,0
- 9	70,5	57,0
- 8	69,0	56,0
- 7	68,0	55,5
- 6	66,5	54,5
- 5	65,0	53,5
- 4	63,5	52,5
- 3	62,5	51,5
- 2	61,0	50,5
- 1	59,5	49,5
0	58,0	48,5
+ 1	56,5	47,5
+ 2	55,0	46,0
+ 3	53,5	45,0
+ 4	51,5	44,5
+ 5	50,0	43,0
+ 6	49,0	42,0
+ 7	49,0	42,0
+ 8	45,0	39,0
+ 9	45,0	39,0
+ 10	45,0	39,0
+ 11	45,0	39,0
+ 12	45,0	39,0
+ 13	45,0	39,0
+ 14	45,0	39,0
+ 15	45,0	39,0